TOWN OF HOLDEN
DEPT. OF PLANNING & DEVELOPMENT
TOWN HALL, 1196 MAIN STREET
PHONE: 508-210-5540
FAX: 508-829-0252

Fax

To: Anisa **From:** Denise

Fax: 774-243-6913 **Pages:** 1

Phone: **Date:** OCTOBER 18, 2016

Re: Certificate of Inspection

☐ **Urgent** ☐ **For Review** ☐ **Please Comment** ☐ **Please Reply**

● Comments:

Hi Anisa,

The Building Inspector went to Dunkin Donuts at 5 Shrewsbury Street in Holden for the annual inspection on August 26, 2016. Several of the emergency lights were not working, therefore the inspector did not issue the certificate. Please have the emergency lights checked and repaired and then call our office for a re-inspection. The current certificate expired on June 30, 2016. Thank you.